**ENERGY AUDIT REPORT OF** SHRI DHARMASTALA **MANJUNATHESHWARA** COLLEGE(AUTONOMOUS), **UJIRE** 

## **CONTENTS**

Sl.No.	Particulars	Page no
1	Introduction	04
2	Necessity of Energy auditing	04-05
3	Methodology	05-06
4	Connected load details	06-28
5	Consolidated load list	28-36
6	Findings and suggestions of energy auditing	36

#### 1. INTRODUCTION

An **energy audit** is an inspection survey and an analysis of energy flows for energy conservation in a building. It may include a process or system to reduce the amount of energy input into the system without negatively affecting the output. In commercial and industrial real estate, an energy audit is the first step in identifying opportunities to reduce energy expense and carbon footprint.

An energy audit comprises of a detailed examination of consumption in electrical power, cost of this power consumption, lastly a suggested program for changes in working practices or power consuming equipment that will effectively saves the cost. The energy audit is a positive involvement with a significant advantage to college. The review process begins by gathering data about facility's operation and about its past record of service bills. This data is then inspecting to realize that how much energy is used and wasted. The energy audit presents the current state of the art regarding work performed related to the electric energy consumption for Information and Communication Technologies (ICT) and Miscellaneous Electric Loads (MELs),in office and commercial buildings. Techniques used for measuring the energy consumption of office plug loads, and efforts for saving energy by using this equipment more rationally and efficiently are identified and categorized.

#### 2. NEED FOR ENERGY AUDIT

In an organization like undergraduate and post graduate degree Colleges, one of the top operating expenses is often found to be electrical energy. In most assessments of the manageability of the cost or potential cost savings in the above component, would invariably emerge as a top priority, and thus energy Audit. Energy constitutes a strategic area for cost reduction. A well-done energy audit will always help owners to understand more about the ways energy is used in their organizations, and help to identify areas where waste can occur and where scope for improvement exists. The energy audit would give a positive orientation to the energy cost reduction, preventive maintenance, and quality control programs which are vital for production and utility activities. Such an audit program will help to keep focus on variations that occur in the energy costs, availability, and reliability of supply of energy, help decide on the appropriate energy mix, identify energy conservation technologies, retrofit for energy conservation equipment, etc.

The primary objective of the energy audit is to determine ways to reduce energy consumption per unit of product output or to lower operating costs. The energy audit provides a benchmark, or reference point, for managing and assessing energy use across the organization and provides the basis for ensuring more effective use of energy.

#### 3. METHODOLOGY

- i. The simple Energy Audit procedures adopted for SDM college campus is as follows
- ii. The details of all the connected loads were collected by visiting each and every room/ floor.
- iii. The approximate working hours of each equipment is identified
- iv. Energy consumption for the connected load is calculated considering the electricity bill
- v. The energy saving option is identified.
- vi. The summary of the audit report is prepared.

#### 4. CONNECTED LOAD DETAILS

The connected load for each area of the college campus is presented here. The load calculation of the campus is done by dividing the whole campus into several blocks as follows

- 1. SDM MAIN BUILDING/GROUND FLOOR
- 2. SDM MAIN BUILDING/FIRST FLOOR
- 3. SDM MAIN BUILDING/SECOND FLOOR
- 4. SEMINAR HALL
- 5. LIBRARY
- 6. SPECIALEQUIPMENTS/LABORATORY
- 7. PG CENTRE/GROUND FLOOR
- 8. PG CENTRE/ FIRST FLOOR
- 9. PG CENTRE/ SECOND FLOOR
- 10. PG CENTRE/ THIRD FLOOR
- 11. DHEEMANTH BOYS HOSTEL
- 12. DHEEMAHI GIRLS HOSTEL
- 13. MESS HALL OF HOSTELS
- 14. SIDDAVANA HOSTEL
- 15. SIDDVANA SPORTS WING
- 16. PHYSICAL DEPARTMENT AND STADIUM
- 17. SDM CANTEEN
- 18. SDM COOPERATIVE STORE



## Sri Dharmasthala Manjunatheshwara College (Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

#### 4.1 SDM MAIN BUILDING/GROUND FLOOR

Table-1 Load details of ground floor

Sl.No.	Name of Equipment	Quantity	Rating of Equipment (W)	Average running hour per day	Energy consumption per month(kWh)
1	Incandescent Bulb	49	60	7	535.08
2	Compact Fluorescent Lamp (CFL)	12	13	8	32.448
3	Fluorescent tube light	112	40	7	815.3
4	T5 tube	30	21	8	131.04
5	Ceiling fan	30	78	7	425.88
6	LED Light	80	13	7	189.28
7	Exhaust fan	12	40	7	87.3
8	Air Conditioner	7	1500	8	2184
		5	1000	8	1040
9	Personnel Computer	51	200	4	1060.8
10	Printer	9	300	4	280.8
11	Fridge	3	150	8	96.6
12	LCD TV	1	155	1	4.03
		1	65	1	1.69
13	Transmitter	1	50	24	31.6





(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

14	Sound Box	2	400	2	41.6
15	UPS in kVA	12	7.5/10/5/8/ 15	1	324.7
	TOTAL				7282.1



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State





### 4.2 SDM MAIN BUILDING/FIRST FLOOR

The below table shows the number of equipment and its total load connected on the  $1^{ST}$  floor of college campus.


Table-2 Load details of first floor

Sl. No.	Name of the equipment	Quantity	Rating of equipment(W)	Average running hour per day	Energy consumption per month(kWh)
1	Incandescent Bulb	16	60	7	174.72
2	Fluorescent tube light	78	40	7	567.84
	Compact fluorescent	1	100	8	2.28
3	light	5	9		9.36
		1	11		2.28
		3	28	0	17.47
4	T5 tube	3	15	8	9.225
		11	20		45.76
		13	40		106.6
5	Ceiling fan	110	78	7	1561.56
		14	20	7	50.96
		3	9	7	4.914
6	LED Light	6	11	7	12.012
	_	4	38	7	27.6
		16	36	7	104.86
		3	1500	8	936.0
7	Air Conditioner	5	1000	8	1040.0
8	Personnel computer	36	200	4	748.8



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State


9	Printer	10	300	4	303.0
10	Projector	11	300	4	343.2
11	Refrigerator	1	250	8	52.0
	Total				6,120.441





(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)



#### 4.3 SDM MAIN BUILDING/SECOND FLOOR

The below table shows the number of equipment and its total load connected on the Second floor of the college campus.

Table -3 Load details of Second floor

SL.NO	Name of the equipment	Quantity	Rating of equipment(W	Average running Hour per day	Energy consumption per month (kWh)
1	Incandescent Bulb	14 1	60 40	7 7	152.8 7.28.
2	Fluorescent tube light	29	40	7	211.12
3	T5 Tube	20	21	8	76.44
4	Ceiling fan	120	78	7	1703.52
5	LED Light	41	20	7	149.24
6	Exhaust Fan	3	40	7	21.84



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)

7	Air Conditioner	1(1T) 1(1.5T)	1000 1500	8 8	208.0 312.0
8	Personal Computer	18	200	4	374.4
9	Printer	17	300	4	530.4
10	Refrigerator	3	150	8	93.6
11	LED TV	5	60	1	7.8
12	Induction Coil	2	900	2	93.6
	TOTAL				3,942.04

## 4.4 SEMINAR HALL


Table-4 Load details of Seminar Hall

Sl no	Name of the equipment	Quantity	Rating of equipment(	Average running Hour per day	Energy consumption per month(kWh)
1	Incandescent Bulb	18	60	4	112.92
2	Compact fluorescent light	2	13	4	2.7
3	Fluorescent tubelight	6	40	4	24.96
4	T5 Tube	1	21	4	2.18
5	Ceiling fan	26	78	4	210.91
6	Air Conditioner	4 (1.5T)	1500	4	624.4
	TOTAL				923.07

### 4.5 LIBRARY

Table-5 Load details of Library

Sl no	Name of the equipment	Quantity	Rating of equipment(W)	Average running Hour per day	Energy consumption per month(kWh)
1	Fluorescent tube light	50	40	8	416.0
2	Compact fluorescent light	2	100	8	41.6
3	T5 Tube	51	50w	8	222.768
4	Ceiling fan	66	78	8	1070.78
5	LED Light	5 7	9 20	8 8	9.36 28.7
6	LED Display	1	5.2	2	0.270
7	Air Conditioner	2(1T )	1000	8	410.0
8	Personal Computer	18	200	8	738.0
9	Induction Coil	1	1.5	8	0.312
10	Water Purifier	1	18	8	0.312
11	Pump	1	5(kva)	2	26.0
12	Ceiling Light	6	20	8	24.96
	TOTAL				2989.062





(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)

### 4.6 SPECIALEQUIPMENTS/LABORATORY

Table-6 Load details of Laboratory

SI no	Name of the equipment	Quantity	Rating of equipment(W	Average running Hour per day	Energy consumption per month(kWh)
1	Oven	1	1200	8	249.6
2	Muffle Furnace	2	2500	8	1040.0
3	Centrifuge	2	250	2	26.0
4	Bunsen Burner	12	350	2	218.4
5	Lumina Airflow	1 1	2000 1200	8 8	410.0 249.6
6	Induction	1	400	8	83.2
7	Bod Incubator	1	400	8	83.2
8	Caloric Meter	10	40	8	83.2
9	Sound System Amplifier	2 1	60 100	4 4	12.12 10.1
10	Hot Air Oven	1	1500	2	78.0
11	Microscope	9	42	2	19.65
12	Amplifier	1 1 6	150 100 40	4 4 4	4.36 10.4 24.2
13	Heater	1	2	2	104.0
14	Led Focus Light	3	10	2	1.56
15	Bell	1	10	2	0.56
16	Show Light	4	40	3	12.48
17	Pedestal Fan	4	11	8	9.0
18	Water Cooler System	4	500	8	410.0



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)

19	Wall Mount Fan	4	100	8	82.0
20	Cooler/Heate r	1	500	8	104.0
	TOTAL				3325.63

### 4.7 PG CENTRE/ GROUND FLOOR


Table-7 Load details of PG CENTRE

Sl no	Name of the equipment	Quantity	Rating of equipment(	Average running Hour per day	Energy consumptionp er month(kWh)
1	Ceiling Fan	44	78	4	356.92
2	Projector	5	300	5	195
3	Closed circuit Camera	3	50	24	93.6
4	LED Bulb	46	20	5	119.6
5	Personal Computer	54	200	4	1123.2
	TOTAL				1888.32



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)



#### 4.8 PG CENTRE/ FIRST FLOOR


Table-8 Load details of PG CENTRE/ FIRST FLOOR

Sl no	Name of the equipment	Quantity	Rating of equipment (W)	Average running Hour per day	Energy consumption per month(kWh)
1	Ceiling Fan	54	78	4	438.04
2	Projector	8	300	5	312
3	Closed Circuit Camera	9	50	24	280.8
4	LED Bulb	53	20	5	137.8
5	Personal Computer	5	200	4	104
	TOTAL				1272.64



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)



#### 4.9 PG CENTRE/ SECOND FLOOR


Table-9 Load details of PG CENTRE/ SECOND FLOOR

SI no	Name of the equipment	Quantity	Rating of equipment (W)	Average running Hour per day	Energy consumption per month(kWh)
1	Ceiling Fan	77	78	4	624.62
2	Air Conditioner	4	1500	4	624
3	Projector	15	300	5	312
4	LED Bulb	65	20	5	169
5	Personal Computer	5	200	4	104
6	Speaker	4	400	2	83.2
	TOTAL				1916.82



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)



#### 4.10 PG CENTRE/ THIRD FLOOR


Table-10 Load details of PG CENTRE/ THIRD FLOOR

Sl no	Name of the equipment	Quantity	Rating of equipment (W)	Average running Hour per day	Energy consumption per month(kWh)
1	Ceiling Fan	78	78	4	632.73
2	Air Conditioner	3	1500	4	468
3	Projector	8	300	5	312
4	LED Bulb	90	20	5	234
5	Personal Computer	1	200	4	20.8
6	Exhaust Fan	8	40	7	58.24
	TOTAL				1717.77



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)



#### **4.11 DHEEMANTH BOYS HOSTEL**


Table-11 Load details of Dheemanth boys hostel

Sl no	Name of the equipment	Quantity	Rating of equipment (W)	Average running Hour per day	Energy consumption per month(kWh)
1	Ceiling Fan	344	78	4	2790.58
2	Closed Circuit Camera	18	50	24	648
3	LED Bulb	498	7	5	1045.8
		501	5	4	63
4	Personal Computer	1	200	4	24
	TOTAL				4571.38

#### **4.12DHEEMAHI GIRLS HOSTEL**

Table-12 Load details of Dheemahi girls hostel

SI no	Name of the equipment	Quantity	Rating of equipment (W)	Average running Hour per day	Energy consumption per month(kWh)
1	Ceiling Fan	321	78	4	2603.95
2	Closed Circuit Camera	5	50	24	180
3	LED Bulb	495	7	5	519.75
		439	5	4	263.4
4	Personal Computer	1	200	4	24
	TOTAL				3591.1



### **4.13MESS HALL OF HOSTELS**


Table- 13 Load details of Mess hall

Sl no	Name of the equipment	Quantity	Rating of equipment (W)	Average running Hour per day	Energy consumption per month(kWh)
1	Fluorescent tube Light	54	40	4	259.2
2	Ceiling Fan	37	78	4	300.14
3	Closed Circuit Camera	6	50	24	216
4	LED Bulb	36	7	5	37.8
5	Personal Computer	1	200	4	24
6	Exhaust Fan	4	40	5	24
7	TV	2	65	7	27.3
	TOTAL				888.44



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)



#### **4.14 SIDDAVANA HOSTEL**


Table-14 Load details of Siddavana hostel

Sl no	Name of the equipment	Quantity	Rating of equipment (W)	Average running Hour per day	Energy consumption per month(kWh)
1	Fluorescent tube	152	60	4	1094.4
	Light				
2	Ceiling Fan	146	78	4	1184.35
3	LED Bulb	9	18	5	24.3
		1	9	4	0.96
4	Personal Computer	10	200	4	24
5	Water Purifier	3	18	24	38.88
	TOTAL				2367.29



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)



#### 4.15 SIDDAVANA SPORTS WING

Table-14 Load details of Siddavana Sports wing


SI no	Name of the equipment	Quantity	Rating of equipment (W)	Average running Hour per day	Energy consumption per month(kWh)
1	LED Focus Light	2	100	4	20.8
2	Fluorescent tube Light	32	60	4	199.68
3	Ceiling Light	22	20	4	45.76
4	Ceiling Fan	52	78	4	421.82
5	LED Show Light	6	5	4	3.12
6	LED Bulb	32	18	5	74.88
7	Personal Computer	1	200	4	20.8
8	TV	1	65	7	11.83
9	Metal Light	1	400	8	83.2



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)

10	LED Gate Light	4	24	7	17.47
11	LED Street Light	11	18	7	36.03
12	Pump	1	5hp	5	484.9
	TOTAL				1420.29



#### 4.16 PHYSICAL DEPARTMENT AND STADIUM

Table- 15 Load details of Physical department and stadium


SI no	Name of the equipment	Quantity	Rating of equipment (W)	Average running Hour per day	Energy consumption per month(kWh)
1	Incandescent	4	40	4	16.64
	Bulb				
2	LED Focus Light	4	100	4	41.6
3	Ceiling Fan	1	78	4	8.11
4	Compact fluorescent lamp	22	11	8	4.57
5	LED Bulb	13	9	5	15.21
		4	20	4	8.32
			20	4	



#### (Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)

6	Personal Computer	1	200	4	20.8
7	Metal Light	2	400	8	166.4
	TOTAL				281.61



#### 4.17 SDM CANTEEN


Table-16 Load details of SDM Canteen

Sl no	Name of the equipment	Quantity	Rating of equipment (W)	Average running Hour per day	Energy consumption per Month (kWh)
1	Grinder	2	3hp	4	465.50
		1	1hp		77.58
2	Fluorescent tube Light	54	40	4	224.64
3	Ceiling Light	16	50	10	208
4	Ceiling Fan	20	78	10	405.6
5	Wall Mount Fan	1	60	4	6.76



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

6	Water	1	1hp	8	155.16
	Cooler				
7	Heater Coil	1	1kw	10	260
		1	2kw		52
8	Fridge	2	5kw	24	6240
9	Mixer Grinder	2	750	5	195
		1	500		65
10	Closed Circuit	6	50	24	187.2
	Camera				
11	LED Bulb	26	9	5	30.42
		11	20		28.6
		22	5		14.3
12	Billing	1	40	10	10.4
	Machine				
13	Exhaust	1	746	5	96.98
	Fan/Motor	1	746	5	96.98
14	Printer	1	60	7	10.92
	TOTAL				8831.04



#### 4.18 SDM COOPERATIVE STORE


Table - 17 Load details of SDM cooperative store

Sl no	Name of the equipment	Quantity	Rating of equipment (W)	Average running Hour per day	Energy consumption per month(kWh)
1	Cooler	1	60	4	6.24
2	Ceiling Fan	7	78	4	56.78
3	Refrigerator	4	300	5	156
4	LED Bulb	4	20	5	10.4
		5	5	5	3.25
		9	9	5	10.53
5	Personal computer	3	200	4	62.4
6	Printer	2	40	5	10.4
7	Inverter	1	1K W	7	182
	TOTAL				498



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)



## **CONSOLIDATED ENERGY CONSUMPTION TABLE**

Sl.No	Item	No. Of items	Power rating	Working hours per day	Monthly consumption in kWh
1	Incandescent Bulbs	102	60W	7	1071
2	Fluorescent tube light	567	40W	7	3969
3	Ceiling Fan	1533	78W	8	23914.8
4	T-5 Tube Light	133	28W	7	651.7
5	Compact Fluorescent Lamp	22	20W	7	77
6	LED lamp	2489	20W	7	8711.5
7	Exhaust Fan	29	50W	4	145
8	Air conditioner 1 T	14	1kW	5	1750
	Air conditioner 1.5T	22	1.94kW	5	5335
9	Personal computer	206	200W	5	5150
10	Printer	38	50W	3	142.5
11	LCD Projector	37	282W	5	1304.25
12	Refrigerator	15	500W	24	4500
13	Scanner	2	25W	4	5
14	Focus light	6	1kW	2	300
15	Halogen Light	2	1kW	7	420
16	LED TV	8	80W	7	112
17	Transmitter	1	50W	24	36
18	Sound box	4	100W	4	40
19	Single phase pump	2	746W	2	74.6
20	Three phase pump	2	2.2kW	3	335.7




## (Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

21	Induction coil	2	900W	2	90
		1	1.5kW	2	24
22	Pedestal Fan	6	60W	4	36
23	Water Purifier	6	60W	24	216
24	Heater	3	1.5 kW	4	450
25	Oven	1	1.2kW	8	240
26	Grinder	3	1kW	4	300
27	Street light	11	100W	10	275
28	Amplifier	8	60W	4	48
29	Microscope	9	42W	9	85.05
30	Bell	3	100W	1	7.5
31	LED focus light	3	100W	3	22.5
32	Photocopy machine	1	183W	7	32.025
33	Show light	4	40W	6	24
34	Muffle Furnace	2	2.5kW	8	1000
35	Centrifuge	2	250W	2	25
36	Incubator	1	400W	8	80
37	Induction stove	1	2kW	8	16
38	Laminar air flow	1	250W	8	50
39	CC camera	53	50W	24	1590
	Total				62656.12



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)



From the above pie chart, it is observed that the energy saving potential is there in replacement of conventional lighting and ordinary fans with energy efficient ones. The detialed floor wise energy saving measure for borth cases is shown in below tables.



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)

## **ENERGY SAVING MEASURES**

#### REPLACEMENT OF CONVENTIONAL LIGHTING SYSTEM INTO LED

AREA	QTY		GHT PE	WAT T	OP (hr)	MONTH LY kWh	CHANG E	NE W WA TTA GE	NE W kW h	SAV ING kWh	SAVI NG Rs	UNIT PRICE (For LED)	INVESTMEN T	PAYBACK (In months)
SDM M BUILDING G FLOC	ROUND	4 9	IN C B U L B	60	7	535.0 8	18W LED Tubelight	ΙX	160. 524	374. 556	3015. 17	200	9800	3



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

	1 1 2	FL T U B	40	7	815.3	18W LED Tubelight	I X	366. 912	448. 38	3609. 52	200	22400	50
SDM MAIN BUILDING FIRST	1 6	IN C B U L B	60	7		18W LED Tubelight	I X	52.4	122. 36	1346. 28	200	3200	19
FLOOR	7 8	FL T U B	40	7		18W LED Tubelight	I X	255. 52	312. 32	2514. 17	200	15600	29
SDM MAIN	1 4	IN	60	7	152.8	18W LED Tubelight	ΙX	45.8 6	106. 94	860.8	200	2800	3
BUILDING SECOND FLOOR	1	C B U L B	40	7	7.28	18W LED Tubelight	18	3.27	4.01	32.28	200	200	6



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

	2 9	FL T U B	40	7		18W LED Tubelight	l IX	95	116. 12	934.7	200	5800	6
SEMINAR HALL	1 8	IN C B U L B	60	4	112.3	18W LED Tubelig ht		33.6	78.6 3	632.9	200	3600	6
	6	FL T U B	40	4	24.96	18W LED Tubelight	I X	11.2	13.7	110.5	200	1200	11
LIBRARY	5 0	FL T U B	40	8	416	18W LED Tubelig ht	18	187. 2	228.	1841. 84	200	10000	5
PHYSICAL DEPT	4	IN C	40	4	16.64	18W LED	18	7.48	9.16	73.73	200	800	11



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)

AND STADIUM	В		Tubelig				
	U		ht				
	L						
	В						

**Total no.of Light fittings = 669 Nos** 

**Total no.of presently operated = 669** 

Nos

Total no. of Light fittings to be

replaced = 669Nos

**Present energy consumption =** 

4870.32 kWh

**Expected energy consumption =** 

2191.64

Total energy saved per month =

2678.67

Total monthly cost savings =

21563.29 Rs

**Investment = 133800 Rs** 

Payback period = 6.20

## **ENERGY SAVING MEASURES**

### REPLACE PRESENT CEILING FAN CONSUMING 78W WITH ENERGY EFFICIENT FANS CONSUMING 40W

AREA	QTY	FAN	WATT	OP (hr)	MONTHLY kWh	CHANG E	NEW WATTAGE	NEW kWh	SAVING (kWh)	SAVING (Rs)	UNIT PRICE (For BLDC FAN) (Rs)	INVEST MENT (Rs)	PAYB ACK (In mont hs)
SDM MAIN BUILDING GROUND FLOOR	30	CEILING FAN	78	7	425.88	28W BLDC FAN	28	152.88	273	2197.65	3250	97500	44
SDM MAIN BUILDING FIRST FLOOR	110	CEILING FAN	78	7	1561.56	28W BLDC FAN	28	560.56	1001	8058.05	3250	357500	44
SDM MAIN BUILDING	120	CEILING FAN	78	7	1703.52	28W BLDC FAN	28	611.52	1092	8790.6	3250	394000	45



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

SECOND FLOOR													
SEMINAR HALL	26	CEILING FAN	78	4	210.91	28W BLDC FAN	28	75.71	135.2	1088.36	3250	84500	78
LIBRARY	66	CEILING FAN	78	8	1070.78	28W BLDC FAN	28	384.38	686.4	5525.52	3250	214500	39
PG CENTRE GROUND FLOOR	44	CEILING FAN	78	7	624.62	28W BLDC FAN	28	224.22	400.4	3223.22	3250	143000	44
PG CENTRE FIRST FLOOR	54	CEILING FAN	78	7	766.584	28W BLDC FAN	28	275.18	491.4	3955.77	3250	175500	44
PG CENTRE SECOND FLOOR	77	CEILING FAN	78	7	1093.09	28W BLDC FAN	28	392.39	700.7	5640.63	3250	250250	44
PG CENTRE THIRD FLOOR	78	CEILING FAN	78	7	1107.28	28W BLDC FAN	28	397.48	709.8	5713.89	3250	253500	44
DHEEMANTH BOYS HOSTEL	344	CEILING FAN	78	12	9659.52	28W BLDC FAN	28	3467.5	6192	49845.6	3250	111800 0	22
DHEEMAHI GIRLS HOSTEL	321	CEILING FAN	78	12	9013.68	28W BLDC FAN	28	3235.6	5778	46512.9	3250	1043250	22
MESS HALL OF HOSTELS	37	CEILING FAN	78	4	346.32	28W BLDC FAN	28	124.32	222	1787.1	3250	120250	67
SIDDAVANA HOSTEL	146	CEILING FAN	78	12	4099.68	28W BLDC FAN	28	1471.6 8	2628	21155.4	3250	45500	2



(Autonomous), Ujire-574 240, Dakshina Kannada, Karnataka State

(Re-accredited by NAAC at "A" grade with CGPA 3.61 out of 4)

SIDDAVANA SPORTS WING	52	CEILING FAN	78	7	851.76	28W BLDC FAN	28	305.76	546	4395.3	3250	169000	38
PHYSICAL DEPT AND STADIUM	1	CEILING FAN	78	4	8.11	28W BLDC FAN	28	2.91	5.2	41.86	3250	3250	78
SDM CANTEEN	20	CEILING FAN	78	10	405.6	28W BLDC FAN	28	145.6	260	2093	3250	65000	31
SDM COOPERATIVE STORE	7	CEILING FAN	78	4	56.78	28W BLDC FAN	28	20.38	36.4	293.02	3250	22750	78

**Total no.of Fan fittings = 1533 Nos** 

**Total no.of presently operated = 1533 Nos** 

**Total no. of Fan fittings to be replaced = 1533 Nos** 

**Present energy consumption = 21762.46 kWh** 

**Expected energy consumption = 7812.16 kWh** 

**Total energy saved per month = 13950.29** 

**Total monthly cost savings = 112299.83 Rs** 

**Investment = 4982250 Rs** 

Payback period = 44.36 months



#### 5. FINDING AND SUGGESTIONS

From the audit the power consumption of various equipment present in the college campus is obtained. It is observed that the energy savings in essential equipment may be done by properly operating them and shutting down when it is not in use. The awareness about energy saving needs to be given to the users of each equipment so that it will save the energy. The energy savings may be done by replacing the existing conventional lights with LED lights and ordinary ceiling fans with BLDC fans. The observations and the suggestions from the audit are as follows.

- 1. Annual maintenance contract (AMC) of UPS and batteries situated in ground floor needs to be renewed every year.
- 2. The socket situated in second floor near the water cooler to be replaced with new one as its indicator is not working properly.
- 3. Overloading of plug socket by using extension chord in sports room of the stadium may be avoided.
- 4. Termination of unused wires to be made by proper lugging.
- 5. Panel at the water pumping to be properly closed after switching on the pump.
- 6. After use each equipments needs to be turned off properly.
- 7. The potential saving of energy is possible in replacement of ordinary ceiling fan of 78 W with Brushless DC fan of 28W and replacing ordinary fluorescent light of 40W with LED light of 18W.
- 8. Annual maintenance contract (AMC) of Air Conditioners and water purifiers situated in various labs and floors needs to be renewed every year.

#### END OF REPORT





# INSTITUTE OF TECHNOLOGY

Affiliated to VTU, Belgavi | Recognized by Govt. of Karnataka | Approved by AICTE, New Delhi

Date: 27/11/2021

# **CERTIFICATE**

This is to certify that the Simple Electrical Energy Audit of Shree Dharmasthala Manjunatheshwara College (Autonomous), Ujire, has been carried out by Assistant Professors Dr. Subrahmanya Bhat and Mr. Santhosh Kumar P N, Department of Electrical and Electronics Engineering, SDM Institute of Technology, Ujire, for the year 2021. The possible energy savings are suggested in the report dated 27/11/2021.

Principal
SDM Institute of Technology

Forwarded